



UNITED

L A B O R A T O R I E S



Ideal for treating lift stations, grease traps and mains, **BIO-ACCEL** stimulates the biodegradation of grease and other organic waste with two-way action.

First, the core of **BIO-ACCEL** is released as a slug dose into the waste stream within minutes. It consists of a critical blend of enzymes designed to accelerate the breakdown of wastes and stimulate biological activity.

Secondly, the outer block of **BIO-ACCEL** is also comprised of a critical blend of enzymes, containing 10,000 IU/gram. It is designed to release these enzymes slowly, providing 60 - 180 days of continuous grease and odor control.

- Easy installation with minimal ongoing attention.
- Eliminates odors.
- Earth Smart® Certified.
- Near neutral pH.
- Ideal for lift stations and grease traps.
- Works at temperature range 38°F to 165°F, with optimum temperature ranges 65°F to 110°F.
- Excellent for grease, scum and oil removal.
- Safe for plant and process...will enhance bacterial process in plant.
- No hazardous components, no VOCs, ranked zero in all HMIS numbers.
- Non-toxic according to EPA, OSHA, NIOSH and WHMIS standards.
- Presents no material safety handling or closed space issues.

DIRECTIONS:

Grease Traps: **BIO-ACCEL** should be suspended in the trap so the block is just under the grease cap. Apply one block for every 350 gallons capacity. If capacity is over 350 gallons, spread the blocks out in different sections of the trap.

United 856

BIO-ACCEL

for Grease and Odor Control in Wastewater Environments with Inter-Core Technology® Patented

KEEP OUT OF REACH OF CHILDREN.
See other cautions on back/side panel

PRECAUCION AL USUARIO:

Si usted no puede leer Ingles, pregunte a alguien que le traduzca esta etiqueta para usted antes de uso.

Manufactured and Sold Exclusively By:
UNITED LABORATORIES, INC.
320 37th Avenue • St. Charles, IL 60174
1-800-323-2594 • www.unitedlabsinc.com

DIRECTIONS: (continued)

Manholes and Mains: In manhole, **BIO-ACCEL** should be placed in the U channel nearly vertically pointed downstream on the upstream end of the U channel.

Lift Stations: **BIO-ACCEL** should be used in low flow applications. Suspend the block so the entire block is submerged below the water at its lowest level.

Lift Station Flow	Number of Blocks
Under 50,000 GPD	1
50,000-100,000 GPD	2

FIRST AID MEASURES:

IF IN EYES: Rinse thoroughly with plenty of water for at least 15 minutes, lifting lower and upper eyelids. Consult a physician.

IF ON SKIN: Wash off immediately with plenty of water for at least 15 minutes.

IF INHALED: Remove to fresh air.

IF SWALLOWED: Clean mouth with water and drink afterwards plenty of water.

An SDS for this product is available through United's website, www.unitedlabsinc.com, providing 24 hour access. Please read the SDS carefully and follow all directions when using or handling this product. Never reuse empty containers. Incompatible materials may adversely react.